



Remote Control (RC) Monitor for Hazardous Locations (ATEX)

Supplemental Instructions for use with RC Monitor Manuals

INSTRUCTION FOR INSTALLATION, OPERATION, AND MAINTENANCE

⚠ DANGER

Understand manual before use. Operation of this device without understanding the manual and receiving proper training is a misuse of this equipment. Obtain safety information at tft.com/serial-number.

This equipment is intended for use by trained and qualified emergency services personnel for firefighting. All personnel using this equipment shall have completed a course of education approved by the Authority Having Jurisdiction (AHJ).

This instruction manual is intended to familiarize firefighters and maintenance personnel with the operation, servicing, and safety procedures associated with this product. This manual should be kept available to all operating and maintenance personnel.

For TFT RC Monitors and Controls intended for use in hazardous locations, the following instructions are applicable IN ADDITION to those provided in the following documents:

- LIY-300 Tornado RC Monitor Manual
- LIX-300 Hurricane RC Monitor Manual
- LIY-050 Typhoon RC Monitor Manual
- LIY-200 Monsoon RC Monitor Manual
- LIY-500 Remote Control (RC) Monitor Electrical Controls

Applicable Hazardous Locations

TFT ATEX RC Monitors and Nozzles are designed, tested and approved for use in Classified Hazardous Locations as defined by European Directive 94/9/EC, commonly referred to as the ATEX Directive. Further classification identifies that Zone 2, Category 3 environments are suitable locations for this equipment. It is important to note that only the TFT RC Monitor and Nozzle are certified for installation in the hazardous area. TFT RC Monitor Operator Stations may be used to control monitor functions, but must be installed outside of the hazardous area. It is the responsibility of the facility design engineer to determine suitable location and connection of components for use in the hazardous environment based on electrical, mechanical, and hydraulic requirements as well as the hazardous location classification.

Product Markings

TFT RC Monitors that are constructed for hazardous location applications will be marked as follows:



II 3 G

TUVNA 21 EX 093

Ex nR T6 Gc IP66/67
-35° C ≤ Ta ≤ +50° C

Restricted Breathing Properties

The test ports provided in the control box enclosure and motor housings are to be used for checking that the restricted breathing properties of the enclosures are retained in service. The restricted breathing properties shall be verified in accordance with the test described in clause 33.7.1 of IEC 60079-15. These test ports must be plugged or sealed during operation. The restricted breathing properties should be checked only when the surrounding atmosphere is known to be nonhazardous.

The test ports consist of an ANSI 10-32 UNF female thread in each of the motor housings and the control box enclosure. Each test port is plugged with a #2 Philips drive screw with O-ring head seal. Do not substitute standard screw. Once testing is complete, verify O-ring head seal is in place and not cut or cracked before replacing screw.

Additional Precautions

Do Not Make Or Break Connections In A Hazardous Area.

Use Only Approved Recommended Power Supply.

Power Supply Should Be Installed In A Non-Hazardous Area.

TASK FORCE TIPS LLC
MADE IN USA · tft.com

3701 Innovation Way, Valparaiso, IN 46383-9327 USA
800-348-2686 · 219-462-6161 · Fax 219-464-7155